

# Dipslides



Guidelines to advise on the correct practices to control legionella bacteria in water systems exist world-wide. Suppressing bacteria levels does substantially reduce the possibility of an outbreak of this often fatal disease. Guidelines recommend introducing a monitoring and control program. This program includes the testing of cooling tower waters with dipslides on a regular basis.

A full range of dipslides is available for semiquantitative determination of aerobic and anaerobic bacteria populations in industrial and recreational waters. Dipslide accuracy is limited due to the small sample size, but if used correctly and incubated at a constant temperature using the Lovibond® dipslide incubator, they are excellent for trend analysis and can give an early indication of bacteria proliferation.

**Dipslide Comparator App**

## Accessories:

Title	Part Number
D001 TTC/TTC Dipslides (pack of 10)	56B010110
D002 TTC/MALT Dipslides (pack of 10)	56B010210
D003 TTC/RBS Dipslides (Rose Bengal) (pack of 10)	56B010310
D004 TTC/MAC Dipslides (Macconkey) (pack of 10)	56B010410
D005 TTC/Chromogenic Dipslides (pack of 10)	56B010510
D006 Pseudomonas (PDM)/MAC Dipslides (pack of 10)	56B010610
D007 Pseudomonas (PDM)/TTC Dipslides (pack of 10)	56B010710
D008 SRB Tube Test (pack of 10)	56B010810
D009 NRB Tube Test (pack of 10)	56B010910
D011 R2A/R2A Dipslides (pack of 10)	56B011110